



ACE TEST HOUSE

(GOVT. APPROVED TESTING LABORATORY)
ISO 9001-2015 OHSAS 45001:2018 ISO 14001:2015
Certified Testing Laboratory



Committed to Precision....

Head Office. Kh. No. 1048/1088, Pepsi Wali Gali, Near Laxmi Narayan Mandir, Village-Bhalaswa, Delhi-110033
.M: +91-7042858881/82/83 E-mail : acetesthouse@gmail.com, website : www.acetesthouse.com



TEST REPORT

(THIS CERTIFICATE IS NOT VALID WITHOUT A HOLOGRAM)

			Page 1 of 1 A0003
Job Card No./ Job I.D. No.	30-20260116-07	Discipline	Chemical Testing
Report No.	ATH30-20260121-005	Group	Water
Sample Type	Drinking Water	Make	--
Name and Address of Customer	Shri Ram Global School, 58/11, PVC Market Road, Tikri Kalan, New Delhi-110041	Grade	--
Reference No.	--	Dated	16-01-2026
Agreement No.	--	Date of Receipt	16-01-2026
Name of Work	--	Start Date of Analysis	17-01-2026
Name of Agency/Contractor	--	End Date of Analysis	21-01-2026
Indian Standard Reference	IS:10500-2012	Report Issue Date	21-01-2026
Any other Information	--	Location	--

Sr. No.	Test Parameter	Unit Of Measurements	Results	Requirement As per IS:10500-2012	Method Reference
Physical Properties					
1)	Colour	Hazen	<5	5.0 Max	IS:3025(Pt-4)-2021
2)	Odour	--	Agreeable	Agreeable	IS:3025(Pt-5)-2018
3)	Taste	--	Agreeable	Agreeable	IS:3025(Pt-7)-2017
4)	Turbidity	NTU	<1.0	1.0 Max.	IS:3025(Pt-10)-2023
5)	pH Value (at 25±2°C)	--	7.22	6.5 to 8.5	IS:3025(Pt-11)-2022
6)	Total Dissolve Solids	mg/l	385	500 Max	IS:3025(Pt-16)-2023
Chemical Properties					
1)	Iron (as Fe)	mg/l	Below Detection Limit	0.3 Max.	IS:3025(Pt-53)-2024
2)	Chloride (as Cl)	mg/l	126.52	250 Max.	IS:3025(Pt-32)-1988
3)	Fluoride (as F)	mg/l	0.15	1 Max.	IS:3025(Pt-60/Sec-1)-2023
4)	Free Residual Chlorine	mg/l	Below Detection Limit	0.2 Min.	IS:3025(Pt-26)-2021
5)	Total Hardness (as CaCO ₃)	mg/l	82	200 Max.	IS:3025(Pt-21)-2009
Micro-Biological Parameters					
1)	Total Coliform Organism	--	Not Detected	Shall not be detectable in 100ml sample	IS: 1622-1981
2)	Escherichia Coli	---	Not Detected	Shall not be detectable in 100ml sample	IS: 1622-1981

Remark : The sample conforms to IS: 10500-2012 w.r.to the above tests.

****End Of Report****



Scan to Verify

Director's Signature
Delhi

Dehradun

Jaipur



Authorised Signatory
Jammu

Terms & Conditions : ① Test reports are valid only for the sample tested in our laboratory. ② Sample will be stored/kept in our stores for 30 days from the date of testing and shall be destroyed thereafter without any intimation. ③ Samples tested are non-returnable in any case ④ This report will not be valid for judicial purpose. ⑤ Total liability of our test house is limited to invoiced amount.